## ADDENDUM No. 3

TO:

**ALL BIDDERS** 

FROM:

CITY OF HIALEAH

RFP#:

2015/16-3210-00-005

RE:

**Reconstruction Of** 

WEST 31<sup>ST</sup> STREET AND WEST 32<sup>ND</sup> STREET FROM

WEST 12<sup>TH</sup> AVENUE TO WEST 9<sup>TH</sup> AVENUE

WEST 11<sup>TH</sup> AVENUE AND WEST 9<sup>TH</sup> AVENUE FROM

WEST 30TH STREET TO WEST 33RD STREET

DATE:

September 8, 2016

The original contract documents for the entitled: Reconstruction of WEST 31<sup>ST</sup> STREET AND WEST 32<sup>ND</sup> STREET FROM WEST 12<sup>TH</sup> AVENUE TO WEST 9<sup>TH</sup> AVENUEWEST 11<sup>TH</sup> AVENUE AND WEST 9<sup>TH</sup> AVENUE FROM WEST 30<sup>TH</sup> STREET TO WEST 33<sup>RD</sup> STREET needs to be amended as noted in this Addendum No. 3.

This Addendum No. 3 consists of 1 typed page, 0 attachment, and 1 addendum receipt form (ARF). All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:

Angel Avala – Purchasing Director

Date: September 8, 2016

### **ACKNOWLEDGMENT**

Receipt of this Addendum No. 3 shall be acknowledged in the space provided on the ADDENDUM RECEIPT form – ARF (Copy attached) now a part of the Contract Documents to be faxed immediately to the City of Hialeah Purchasing Division (305) 883-5871 and submitted with sealed bids.

## QUESTIONS AND ANSWERS:

## Kailas Contractors.

- Q1. What type of pipe is proposed for the drainage system? Can the contractor utilize pipe options approved by FDOT?
- A1. The Contractor may utilize pipes approved by FDOT.
- Q2. Several places in the specs refer to 1991 fdot road and bridge specifications. Can you please confirm if the year stated is a typo?
- A2. The Contractor is to refer to FDOT Standard Specifications for Road and Bridge Construction 2016.
- Q3. It is common practice for the owner to provide \$ allowances for items such as; contingency and pole removal by FPL. Can the owner entertain this for this bid?
- A3. Contingency is to be left blank, The eCity of Hialeah will set the contingency money amount prior to awarding project. FPL will pay for the removal or relocation of any poles, except for luminaires on FPL poles.

Addendum No. 3
Page 1 of 1
END OF ADDENUM No. 3

# **CITY OF HIALEAH**

Reconstruction Of
WEST 31<sup>ST</sup> STREET AND WEST 32<sup>ND</sup> STREET FROM
WEST 12<sup>TH</sup> AVENUE TO WEST 9<sup>TH</sup> AVENUE
WEST 11<sup>TH</sup> AVENUE AND WEST 9<sup>TH</sup> AVENUE FROM
WEST 30<sup>TH</sup> STREET TO WEST 33<sup>RD</sup> STREET

# **ADDENDUM No. 3**

CONTRACTOR'S NAME		
PHONE NO.		
CONTACT NAME	SIGNATURE	
	S RECEIPT OF THE FOLLOWING ADDENDU ed immediately to the City of Hialeah at (30	
ADDENDUM	SIGNATURE	DATE
3		<del></del>